

ATTACHMENT “A”

Loaned extinguishers shall be provided at no charge for each extinguisher removed for repair or inspection. The loaner shall be of same type and size.

National Fire Protection Association (NFPA) verification collars are required.

Annual service inspections will be upon request of Milwaukee County and shall include but not be limited to the following:

- | | |
|--|---|
| <ul style="list-style-type: none">_ Check Pressure Gauge_ Check Pressure Relief Disc (CO2)_ Weigh Units_ Check Shell_ Repaint Small Scratches_ Inspect Hanger Attachment_ Clear Unit_ Check Dates for Internal & Hydrostatic Retest_ Check Nozzle/Hose or Discharge Nozzle_ Remove and Check Hose or Discharge Nozzle | <ul style="list-style-type: none">_ Brush Threads or Lubricate_ Clear Hose_ Flex and Check Hose_ Inspect Hose or Nozzle for Damage_ Check Couplings_ Check Bracket_ Attach New Tag_ Check Discharge Valve_ Remove and Check Pull-pin_ Check Cam Lock Adjustment_ Change Seal_ Clean Handle and Lever |
| <ul style="list-style-type: none">_ Hydro units requiring testing, when returned to the shop we will receive free loaners._ On the spot service for recharge and internal inspection_ The following services are required for each test:<ul style="list-style-type: none">- Conduct a full discharge test- Siphon tube from valve- Check for damage- Clear tube- Check proper length | <ul style="list-style-type: none">_ Valve Service_ Clean and Check Stem Shaft O-Ring_ Clean O-Ring groove_ Clean valve stem_ Clean spring_ Lubricate O-Rings and stem_ Clean and check valve body threads_ Clean vent hole_ Shell- interior inspection_ Empty contents_ Inspect by suitable light_ Clean seams and check_ Clean and examine neck threads_ Reassemble and leak test. Recharge |